


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 954Date: 9/6/23

It is certified that an inspection team headed by Mr. B. S. JUDAN (Name of Officers with designation) from P.H.E. Pro-sub division (Name of Department/Office) inspected the SANSKAR ACADEMY SCHOOL, GUNA ROAD, BARKHEDE (Name & Address of the School) on _____ and found that the SANSKAR ACADEMY SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 09/06/2024.


 Signature with Seal : Assistant Engineer
 Name : ~~Chandr Prakash~~ Ashoknagar (M.P.)
 Designation : _____

To

SANSKAR ACADEMY
SCHOOL
ASHOKNAGAR
 (Name & Address of the Institution)

DISTRICT WATER TESTING LABORATORY,

Public Health Engineering Department (PHED) Store,
Pathar Mohalla, District Ashoknagar (M.P.)

Test Report

Nature Of Sample	Drinking Water Sample	Not-Sampled by Division Water testing Lab. Ashoknagar	Unique Identification No.
Sender's Name & Address		Sender's Letter No.	Sender's Letter date.
संस्कृत एकेमी स्कूल गुमा रोड - अशोकनगर (म.प्र.)		DWTL Letter Receipt No.	DWTL Letter Receipt Date.
		Date of Analysis started	Date of Analysis Completed
		Quantity of Sample.	

Sample Details :

S.No	Block	Gram Panchayat	Village	Location	Source
1	अशोकनगर	अशोकनगर	-	स्कूल परिसर	वेर
2	-	-	-	-	-

Physical & Chemical Test Report With Details Of Parameters Their Test Methods, Units And Specification as per BIS.

S.No	Characteristics	Unit	As Per BIS 10500:2012 & Reaffirmed in sep. 2018		Test Result	
			Requirement (Desirable Limit)	Permissible Limit in the absence of alternate Source	Sample Numbers	
					1	2


PHYSICAL TEST

1	Temperature	C	-	-	-	-
2	Turbidity	NTU	1	5	1.8	-
3	Colour	Hazen Unite	5	15	7	-
4	Test and odour	-	Unobjectionable	Unobjectionable	Unobj -	-

CHEMICAL TEST

5	pH Value	pH Scale	6.5 - 8.5	No relaxation	7.4	-
6	Total Alkalinity (as CaCO ₃)	mg/l	200	600	190	-
7	Chlorides	mg/l	250	600	255	-
8	Nitrates	mg/l	45	45	8	-
9	Total Hardness (as CaCO ₃)	mg/l	200	600	248	-
10	Calcium (as Ca)	mg/l	75	200	52.4	-
11	Magnesium (as Mg)	mg/l	30	100	32.2	-
12	Total Dissolved Solids (T.D.S.)	mg/l	500	2000	380	-
13	Fluoride	mg/l	1	1.5	0.3	-
14	Iron	mg/l	0.3	1	0	-
15	Arsenic	mg/l	0.01	0.01	0	-
16	Total Coliform	Per 100ml	0	0	0	-
17	E-coli	Per 100ml	0	0	0	-
18	Manganese	mg/l	0.01	0.03	-	-
19	Sulphate	mg/l	200	400	-	-
20	Residual Chlorine	mg/l	0.2	1	-	-

Remark:- According to the test Water of given Sample is **Fit / Unfit** for drinking Purpose.


 Chemist
 District Water Testing Laboratory
 P.H.E.D. Ashoknagar (M.P.)


 Assistant Engineer
 Public Health Engineering Department
 Sub Division Ashoknagar (M.P.)
 Issue / Dispatch Date

Issue / Dispatch Date: Ashoknagar / P.H.E.D. / Ashok Nagar / 2023